


EMT Initiative: Applications and Pilots WG ISO/RTO perspectives & challenges

Harvey Scribner
Southwest Power Pool
10/07/2025

ORNL is managed by UT-Battelle, LLC for the US Department of Energy



U.S. DEPARTMENT OF
ENERGY



Key EMT Applications in SPP

- **Current Uses:**

- Generator Interconnections (in weak grids)
- HVDC Interconnection Planning and Design

- **Planned Uses:**

- High Impact Large Load Interconnections (data centers, EV hubs)
- Grid-Enhancing Technologies (GETs): Advanced Power Flow Controllers
- MT-HVDC Transmission Planning and Design

EMT for Generator Interconnections (GI)

- **Use Case:**

- Required when GSAT (SCR, WSCR, etc.) flags weak grid

- **Model Requirements:**

- EMT model compliance with SPP EMT Model Requirements
- Pass 12 technical tests (e.g., ride-through, P/Q control)

- **Key Studies:**

- EMT dynamic performance study (Running TPL-001-5.1 contingencies)

- **Challenges:**


- Model validation and developer coordination
- Lack of detailed system-wide EMT models

SPP GI Queue, ISD 2030

GEN TYPE	Requests	GW Capacity
Battery / Storage	144	21 GW
Hybrid	59	12 GW
Solar	223	47.7 GW
Thermal	20	3.5 GW
Wind	115	27.4 GW
TOTAL	561	111.5 GW

EMT for HVDC Interconnections

- **Use Case:**
 - Required for all HVDC projects
- **Model Requirements:**
 - Like GI (previous slide)
- **Key Studies:**
 - EMT dynamic performance study
 - Emergency Power Control
 - Grid-Forming Assessment
 - Fault Ride-Through
 - SSO & Converter-Driven Stability
- **Challenges:**
 - Like GI (previous slide)



EMT for Large Load (>10 on 69kV, >50 MW above 69kV)

- **Use Case:**

- Under development for loads like Data centers, EV hubs, and electrolyzers

- **Model Requirements:**

- Like GI (previous slide)

- **Key Studies:**

- EMT dynamic performance study
- Harmonic impact and flicker
- Fault Ride-Through
- SSO & Converter-Driven Stability

- **Challenges:**

- Like GI (previous slide)
- High Fidelity EMT models

- **Planned Timeline:**

- 2025–2026

SPP Requests:

- Received: 26.36 GW
- In Service Date: 2027
- Added to Service Agreement: 7.05 GW

LL Requests. Received= 2581.02 MW
LL Requests Added to SA= 550.00 MW

LL Requests. Received=2145.21 MW
LL Requests Added to SA=759.00MW

LL Requests. Received=1577.49 MW
LL Requests Added to SA=1019.85MW

LL Requests. Received=6302.80 MW
LL Requests Added to SA=2300.00MW

LL Requests. Received=13758.08 MW
LL Requests Added to SA=2426.66 MW



Future Applications & Trends

- Grid-Enhancing Technologies (GETs): Advanced Power Flow Controllers
- High Impact Large Load (HILL)
- Multi-Terminal HVDC EMT Simulation
- Multi-Domain Simulation & Advanced Inverter Modeling
- EMT Simulations for SPP Operation

Thank you